



SEGREGATION GUIDE

AS3833:2007 The Storage and Handling of mixed classes of Dangerous Goods...

	CLASS	CLASS 2			CLASS 4			CLASS 5		CLASS 6	CLASS 8
											
COMPRESSED GASES	2.1 Flammable		Compatible	KEEP APART	Segregate from	Segregate from	Segregate from	Segregate from	ISOLATE	KEEP APART	KEEP APART
	2.2 Non-flammable/non-toxic		KEEP APART	Compatible	Segregation may be necessary	Segregate from	Segregation may be necessary	Segregation may be necessary	Segregate from	Segregation may be necessary	KEEP APART
FLAMMABLE LIQUIDS (and Combustible liquids)	3		Segregate from	KEEP APART	Compatible	Segregate from	Segregate from	Segregate from	ISOLATE	KEEP APART	KEEP APART
FLAMMABLE SOLIDS	4		Segregate from	Segregation may be necessary	KEEP APART	Segregation may be necessary	KEEP APART	Segregation may be necessary	KEEP APART	Segregation may be necessary	KEEP APART
4.1 Flammable solids			Segregate from	Segregation may be necessary	KEEP APART	Segregation may be necessary	KEEP APART	Segregation may be necessary	KEEP APART	Segregation may be necessary	KEEP APART
4.2 Spontaneously combustible			Segregate from	Segregation may be necessary	KEEP APART	Segregation may be necessary	KEEP APART	Segregation may be necessary	KEEP APART	Segregation may be necessary	KEEP APART
4.3 Dangerous when wet			Segregate from	Segregation may be necessary	KEEP APART	Segregation may be necessary	KEEP APART	Segregation may be necessary	KEEP APART	Segregation may be necessary	KEEP APART
OXIDIZING SUBSTANCES	5		Segregate from	Segregation may be necessary	Segregate from	Segregation may be necessary	KEEP APART	Segregation may be necessary	KEEP APART	Segregation may be necessary	KEEP APART
5.1 Oxidizing agents			Segregate from	Segregation may be necessary	Segregate from	Segregation may be necessary	KEEP APART	Segregation may be necessary	KEEP APART	Segregation may be necessary	KEEP APART
5.2 Organic peroxides			ISOLATE	Segregate from	Segregation may be necessary	Segregation may be necessary	KEEP APART	Segregation may be necessary	KEEP APART	Segregation may be necessary	KEEP APART
TOXIC SUBSTANCES	6		KEEP APART	Segregation may be necessary	KEEP APART	Segregation may be necessary	KEEP APART	Segregation may be necessary	KEEP APART	Segregation may be necessary	KEEP APART
CORROSIVE SUBSTANCES	8		KEEP APART	KEEP APART	KEEP APART	Segregation may be necessary	KEEP APART	Segregation may be necessary	KEEP APART	Segregation may be necessary	KEEP APART

LEGEND:

	Dangerous goods of the same Class should be compatible; consult MSDS or suppliers about requirements for individual substances.
	Dangerous goods of the same Class could be incompatible or react dangerously. Consult the MSDS or suppliers about requirements for individual substances.
	Segregation of these Classes may be necessary. Consult the MSDS or supplier.
	Dangerous goods of these Classes should be kept apart by at least 3 m. Consult the MSDS or supplier.
	These combinations of dangerous goods should be segregated by at least 5 m and kept in separate compounds or building compartments.
	This requirement applies to organic peroxides, for which dedicated stores or storage cabinets are recommended. Adequate separation from other buildings and boundaries is required.

NOTES:

- In all cases, the MSDS or supplier of the goods should be consulted.
- The segregation of dangerous goods of Division 1.4S may be necessary. Consult the MSDS or the supplier of the goods.
- Combustible liquids shall be segregated in the same manner as flammable liquids of Class 3.
- Dangerous goods of Class 9 should be segregated in accordance with MSDS.
- If the dangerous goods have a Subrisk of another class, then the segregation requirements for the Subrisk need to be determined and the more stringent segregation requirements applied.
- Where smoke detectors are to be stored, their supplier should be consulted and any specific storage and handling recommendations followed.